



**SILENT
KNIGHT**

**Model C-6000 Fire Control/Communicator Panel
Operating Instructions**

These instructions must be framed and displayed next to the C-6000 panel in accordance with NFPA 72 fire code for Local Protected Fire Alarm Systems.

Function	Keystrokes
Silence alarms or troubles	[SILENCE] (+ Code @ 5230)
Reset alarms (or smoke det.)	[1] [ENTER] (+ Code @ 5230)
Reset dialer	[3] [ENTER] + Installer's Code (always required)
Display event memory	[5] [ENTER] (+ Code @ 5230)
Clear event memory	[2] [ENTER] + Installer's Code (always required)
Display troubles	[6] [ENTER] (+ Code @ 5230)
Begin fire drill	[2] [0] [ENTER] + Code (either Operator's or Installer's, always required)
End fire drill	[SILENCE] (+ Code @ 5230)
Disable/Enable a Zone	Zone # + [DISABLE] + Code (Either Operator's or Installer's, always required.)
Communication test	[0] [ENTER] (+ Code @ 5230)
Walk test	[2] [2] [ENTER] + Installer's Code (always required)

Note: Press [CLEAR] to start over if you make a mistake.

Function	Keystrokes
Start download	[4] [ENTER] [Installer's Code]
Set date	[8] [ENTER] [Code] + 6 digits for date (Either Operator's or Installer's Code always required.)
Set time	[9] [ENTER] [Code] + 4 digits for 24-hr military time (Either Operator's or Installer's Code always required.)
Enter programming mode	[2] [7] [ENTER] + Installer's Code (always required)
Exit test or program modes and return to normal operation.	Using 5230: [STEP] [STEP] [CLEAR] [CLEAR] Using built-in annunciator: [SILENCE] [SILENCE] [CLEAR] [CLEAR]

For service call: